

---

**ENC: Informações sobre o Nobreak (019.16675.2026.0023644-01)**

---

**De** Bruna Celli Goes Lima Santos <bruna.lima@saude.ba.gov.br>

**Data** Qua, 29/04/2026 17:11

**Para** HRDB Compras <hrdbalmoxarifado@gmail.com>; Rodrigo Oliveira Neves <rodrigo.neves@saude.ba.gov.br>

---

**De:** Yan Santos Oliveira <yan.oliveira@saude.ba.gov.br>

**Enviado:** quarta-feira, 29 de abril de 2026 11:33

**Para:** Bruna Celli Goes Lima Santos <bruna.lima@saude.ba.gov.br>

**Cc:** André Luís de Santana Santos <andre.santos@saude.ba.gov.br>

**Assunto:** Informações sobre o Nobreak (019.16675.2026.0023644-01)

Prezada,

Segue reforço das especificações imprescindíveis para o nobreak 3,2 kVA (019.16675.2026.0023644-01):

- Fator mínimo de potência: **0,7**.
- Forma de onda: **senoidal pura em ambos os modos (rede e inversor)**; não será aceita forma semi-senoidal/PWM.
- Autonomia da bateria: **mínimo de 20 minutos utilizando a carga máxima** (100% da capacidade nominal do nobreak).

Atenciosamente,



The image shows a business card for Yan Santos Oliveira. On the left side, there are logos for HRDB (Hospital Regional Dantas Bião), the Government of Bahia (GOVERNO DO ESTADO BAHIA), and the Secretary of Health (SECRETARIA DA SAÚDE). The slogan 'GOVERNO PRESENTE FUTURO PRA GENTE' is at the bottom. On the right side, the name 'Yan Santos Oliveira' is written in blue, followed by 'Analista de Sistemas' and 'Hospital Regional Dantas Bião - HRDB'. Contact information includes a phone number '(75) 34035711 | Setor TI' and an email address 'yan.oliveira@saude.ba.gov.br'.