



Quadro de Cargas													
QDGL													
Circ.	Descrição	Iluminação		Pot. V	Pot. A	Demanda c23	Fat. Pot.	Corr. A	Fases	Prot. A	Cond. mm2	Fases ABC	Obs.
		50W	200W										
1	Circuito 1	6		12000	1263,2	100%	0,95	5,74	1	10A	2,5	A	Obs.:
2	Circuito 2	9		18000	1894,7	100%	0,95	8,61	1	10A	4	A	Obs.:
3	Circuito 3	4		2000	210,5	100%	0,95	0,96	1	6A	2,5	A	Obs.:
RES.	Circuito Reserva												-
RES.	Circuito Reserva												-
Total		4	15	32000	3368,4								
Aliment.	C=10m OT=2%			32000	3368,4	100%	0,95	15,30	1	25A	10	A	-
Potência Demandada: 100% (3200,0 W) (3368,4 V.A)													
												Corrente nas Fases: A=15,3A	

